

## City of Savannah Utility Department Water Quality Report for 2022

### Is my drinking water safe?

Yes, our water meets all of EPA's health standards. We have conducted numerous tests for over 80 contaminants that may be in drinking water. As you will see in the chart on the back, we only detected **9** of these contaminants. We found all of these contaminants at safe levels.

### What is the source of my water?

Your water, which is ground water comes from a well field located within the Lower Tennessee-Beech watershed.. Our goal is to protect our water from contaminants, and we are working with the State to determine the vulnerability of our water source to **potential** contamination. The Tennessee Department of Environment and Conservation (TDEC) has prepared a Source Water Assessment Program (SWAP) Report for the untreated water sources serving water to this water system. The SWAP Report assesses the susceptibility of untreated water sources to **potential** contamination. To ensure safe drinking water, all public water systems treat and routinely test their water. Water sources have been rated as reasonably susceptible, moderately susceptible, or slightly susceptible based on geologic factors and human activities in the vicinity of the water source. The City of Savannah **Utility Department** sources rated as reasonably susceptible to potential contamination.

An explanation of Tennessee's Source Water Assessment Program, the Source Water Assessment summaries, susceptibility scorings and the overall TDEC report to EPA can be viewed online at <https://www.tn.gov/environment/program-areas/wr-water-resources/water-quality/source-water-assessment.html> or you may contact the Water System to obtain copies of specific assessments.

A wellhead protection plan is available for your review by contacting JAMES MATTHEWS at the CITY OF SAVANNAH WATER PLANT between 7:00 A.M. to 4:00 P.M. weekdays at 731-925-4930.

### Why are there contaminants in my water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

**Este informe contiene información muy importante. Tradúscalo o hable con alguien que lo entienda bien.**

**For more information about your drinking water, please call JAMES MATTHEWS at 731-925-4930**

### How can I get involved?

Our Utility Board meets on the third Monday at 5:30 P.M. at the Savannah City hall. Please feel free to participate in these meetings.

### Is our water system meeting other rules that govern our operations?

The State and EPA require us to test and report on our water on a regular basis to ensure its safety. We have met all these requirements. Results of unregulated contaminant analysis are available upon request. We want you to know that we pay attention to all the rules.

### Other Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and the Tennessee Department of Environment and Conservation prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

### Do I Need to Take Special Precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have under-gone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about not only their drinking water, but food preparation, personal hygiene, and precautions in handling infants and pets from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

### Lead in Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Savannah **Utility Department** is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <https://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water>

### Water System Security

Following the events of September 2001, we realize that our customers are concerned about the security of their drinking water. We urge the public to report any suspicious activities at any utility facilities, including treatment plants, tanks, fire hydrants, etc. to 731-925-4930 or 911.

## W a t e r   Q u a l i t y   D a t a

### What does this chart mean?

- MCLG - Maximum Contaminant Level Goal, or the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- MCL - Maximum Contaminant Level, or the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.
- MRDL: Maximum Residual Disinfectant Level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for the control of microbial contaminants.
- MRDLG: Maximum residual disinfectant level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- AL - Action Level, or the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- Below Detection Level (BDL) - laboratory analysis indicates that the contaminant is not present at a level that can be detected.
- Non-Detects (ND) - laboratory analysis indicates that the contaminant is not present.
- Parts per million (ppm) or Milligrams per liter (mg/l) – explained as a relation to time and money as one part per million corresponds to one minute in two years or a single penny in \$10,000.
- Parts per billion (ppb) or Micrograms per liter - explained as a relation to time and money as one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Contaminant	Violation Yes/No	Level Found	Range of Detections	Date of Sample	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Arsenic	NO	0.0007	0.0007 *	2020	ppb	N/A	10 ppb	Erosion of natural deposits, and runoff
Copper	NO	90 <sup>th</sup> % =0.22	.0017 to 0.224	2020	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Fluoride	NO	0.98	0.30 TO 0.98	2022	ppm	N/A	4.0	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead <sup>4</sup>	NO	90 <sup>th</sup> % 1.4	.001 to 0.0014	2020	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Sodium	NO	5.88	5.88 *	2020	ppm	N/A	N/A	Erosion of natural deposits; used in water treatment
TTHM <sup>6</sup> [Total trihalomethanes]	NO	26.4	10.5 TO 26.4	2022	ppb	N/A	80	By-product of drinking water with chlorination
Chlorine	NO	2.1	0.83 TO 2.10	2022	ppm	MRDLG 4	MRDGL = 4	Water additive used to control microbes.
Total Coliform Bacteria	NO	0	N/A	2022	% POSTIVE SAMPLE	0	0 POSITIVE SAMPLE	Naturally present in the environment
Haloacetic Acids (HAA5)	NO	9	1 to 9	2022	ppb	N/A	60	By-product of drinking water disinfection.

<sup>4</sup> During the most recent round of Lead and Copper testing, 0 out of 30 households sampled contained concentrations exceeding the action level. PPB: parts per billion or micrograms per liter, PPM: parts per million or milligrams per liter, N/A: not applicable, AL: action level or the concentration of a contaminant which, when exceeded triggers treatment or other requirements which a water system must follow. About the date: Most of the data presented in this table is from testing done between January 1 and December 31, 2022. We monitor for some contaminants less than once per year, and for those contaminants, the date of the last sample is shown in the table.

\*ARSENIC AND SODIUM we only required to collect one sample.

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (1-800-426-4791).

<sup>6</sup> While your drinking water meets EPA's standard for trihalomethanes, it does contain low levels. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.